



# SOUTHERN POWER DISTRIBUTION COMPANY OF T.S LIMITED

From,  
THE SUPERINTENDING ENGINEER  
OPERATION  
RANGA REDDY NORTH CIRCLE  
TSSPDCL  
HYDERABAD

To  
✓ M/S. C.M.R EDUCATIONAL SOCIETY  
SY.NO.592 & 593,MAISAMMAGUDA/V  
GUNDLA POCHAMPALLY,  
R.R.DIST  
II

LR.NO SE/OP/RRC(N)/TECH/D NO 1541/15-16.DT.01-02-2016

Sub:- Extension of HT Supply at 11 KV under Cat-II for an addl CMD of 30 KVA without change in CL over and above the existing CMD 70 KVA with a CL of 100 KW making a total CMD of 100 KVA with a CL of 100 KW to M/s. C.M.R Educational Society., (RRN-20 01), at Sy.Nos. 592 & 593, Maisammaguda (V), Medchal (M) in Medchal Town Section of Medchal Sub-Division in Medchal Division in Ranga Reddy Circle (North)

Ref No: SANCTION MEMO.NO.SE/OP/RRC(N)/TECH/D.NO.1540/15-16,DT.01-02-2016  
Estimate Number: E-2015-07-03-11-01-088

The permission accorded is subjected to the following conditions:

1. The work should be executed by a Licensed Contractor as per the standards of TSSPDCL under supervision THE ASSISTANT DIVISIONAL ENGINEER OPERATION MEDCHAL SUB-DIVISION
2. The material used in the work should confirm to TSSPDCL specifications.
3. If unforeseen calamities/ accidents occur during the execution of work, the TSSPDCL authorities are not held responsible for such incidents and consequential losses or damages. It is the responsibility of the consumer for any loss of material utilised in completing the work till all the services contemplated in the proposal are released.
4. Major materials like AB Switches, HG Fuse sets, Conductor, Structure steel and other materials should be purchased as per TSSPDCL specifications along with test certificate from TSSPDCL vendor. The bills/voucher of materials purchased along with test certificate should be produced to concerned CSC/ICSC before execution of work.
5. The work will be executed as per the sketch enclosed. The work executed by consumer shall be taken over by the TSSPDCL after statutory TSSPDCL after statutory inspection of TSSPDCL officials. The installation shall be deemed to the property of TSSPDCL after such takeover.
6. The consumer should provide sealing arrangement for control panel and meeting equipment.
7. The consumer shall clear off the dues of UDC/Bill stopped services if any existing in the premises or found at a later date and no court cases pending. If any legal disputes arise electricity supply will be disconnected to the premises.
8. There should not be any 11 KV /LT lines passing through from other source of supply in the proposed premises.
9. Distribution Transformer will be provided by the TSSPDCL by collecting the cost of DTR/Development charges whichever is higher.
10. Obtaining CEIG/CEA approval for electrical installing. Obtaining NOC as per requirement of A.P Fire Services act 1999, Multi-storied building regulations.
11. No service connection shall be released for Multi storied buildings / Complexes greater than 10Mtrs in height unless occupancy certificate from concerned authorities.
12. You are requested to pay the following charges through a single DD in the Customer Service center / Integrated Customer Service center
 

A. Incidental charges i.e	Rs. 0.00
B. Development charges / cost of the DTR	Rs. 36,000.00
C. Security deposit charges	Rs. 30,000.00
D. Cost of Materials	Rs. 0.00
E. 6% of DTR cost	Rs. 0.00
F. Application Fee	Rs. 0.00
G. PTR Cost	Rs. 0.00
<b>Total Amount</b>	<b>Rs. 66,000.00</b>
13. You are requested to pay an Amount Rs. 66,000.00 in shape of Demand Draft in favour of TSSPDCL Payable at HYDERABAD and handed over to In charge of C.S.Center/Integrated C.S.Center.
14. D.D must be received to concerned CSC within 60 days from D.D issue date.
15. Payments must be received before 01-05-2016 , If not received existing registration will be cancelled.
16. Work must be completed before 30-07-2016 , If not completed you have to forfeit the already paid amount.

SD/-

SUPERINTENDING ENGINEER

PRINCIPAL

Malla Reddy Engineering College  
(Autonomous)

Maisammaguda, Dhulapally,  
(Post Via Kompally), Sec'bad-500 100



# SOUTHERN POWER DISTRIBUTION COMPANY OF T.S. LIMITED

Office of  
THE SUPERINTENDING ENGINEER  
OPERATION  
RANGA REDDY NORTH CIRCLE  
TSSPDCL  
HYDERABAD

SANCTION MEMO NO. SE/OP/RRC(N)/TECH/D.NO.1540/15-16.DT.01-02-2016

Sub:- Extension of HT Supply at 11 KV under Cat-II for an addl CMD of 30 KVA without change in CL over and above the existing CMD 70 KVA with a CL of 100 KW making a total CMD of 100 KVA with a CL of 100 KW to M/s. C.M.R Educational Society., (RRN-20 01), at Sy.Nos. 592 & 593, Maisammaguda (V), Medchal (M) in Medchal Town Section of Medchal Sub-Division in Medchal Division in Ranga Reddy Circle (North) - Estimate sanctioned.

Ref : Estimate Number: E-2015-07-03-11-01-088

The above estimate is administratively approved and technically sanctioned and registered as DR.NO.298/15-16

**The sanction accords is subject to the following conditions:**


1. TSSPDCL after careful examination of the above proposal hereby accords approval for the scheme at a cost of 0.80.
2. In exercise of the powers conferred under section 42.1 of the Electricity Act, 2003 Central Act. No.36 of 2003 it system in his area of supply and to supply electricity in accordance with the provisions contained in this act.
3. The sanction accorded in para-1 above is subject to instructions issued already on release of service and tariff as may be in force from time to time.
4. The expenditure is chargeable to TSSPDCL-Capital Receipts and Expenditure- B, Expenditure-2 Transmission Lines (Including Sub Stations) ... Distribution System (Including Sub-Stations) capital works in progress Transmission plant (Extra High Voltage A/C. No.0204) Distribution System (High Voltage A/C. No.0204) Distribution System Medium Voltage (A/C. No.0206) Street Lighting.
5. The work will be executed by THE ASSISTANT DIVISIONAL ENGINEER OPERATION MEDCHAL SUB-DIVISION and all necessary approvals and payments must be ensured before release of supply.
6. Consumer has to pay the following charges through a single DD In the Customer Service Center / Integrated Customer Service Center:

A. Serviceline charges	Rs. 1.00
B. Development charges	Rs. 36,000.00
C. Initial Consumption Deposit	Rs. 30,000.00
D. Application Fee	Rs. 0.00
E. PTR Cost	Rs. 0.00

**Total Amount** Rs. 66,001.00

SD/-

SUPERINTENDING ENGINEER

  
**PRINCIPAL**  
Ranga Reddy Engineering College  
(Autonomous)  
Maisammaguda, Dhulapally,  
(Post Via Kompally), Sec'bad-500 100



## Estimate Cost Calculation Sheet

WBS Element : E-2015-07-03-11-01-088  
 Work Executed by : CONSUMER  
 Service Connection Estimate : NO  
 WBS Desc.: HT20011996 Estimate for e/s under 11KV H  
 Estimate Plan Cost : 0.80

CSC Registration Number	Applicant Name	HT/ LT	Cat.	Sub-cat./ Volt.	Con. load	Cat.	Con. load	Bl. Monthly	All Doc. Received	No of Shifts	Exst. load	Exst. Cat	Exst. SD
HT20011996	M/S. C.M.R EDUCATIONAL SOCIETY	HT	02	011	100				X	2	70		0

### SD Calculation:

CSC Registration Number	Cat.	Cont. load	Tariff S.D	Tariff D.C	Cat.	Cont. load	Tariff S.D	Tariff D.C	No. of Times S.D	No of Shifts	S.D Charges	Development Charges
HT20011996	02	30	1000	1200					1	2	30,000	36,000
Total	00	0									30,000	36,000

### DC Calculation:

DC as per Load : 36,000.00  
 Final Dev. Charges : 36,000.00

14% Service Tax on Services : 0.10  
 Total (Gross cost - 14% ST) : 0.70

Development charges / Cost of the DTR : 36,000.00  
 Security deposit charges : 30,000.00  
 Application Fee : 0.00  
 PTR Cost : 0.00  
**Total Amount : 66,000.00**

**PRINCIPAL**  
 Malla Reddy Engineering College  
 (Autonomous)  
 Maisammaguda, Dhulapally,  
 (Post Via Kompally), Sec'bad-500 100



Estimate for extension of 11KV HT supply under-II for an Addl CMD of 30KVA without change in CL over and above the existing CMD of 70KVA with a CL of 100KW making a total CMD of 100KVA with a CL of 100KW to M/S.C.M.R. Educational Society (RRN-2001) at Sy.no.592 & 593, Mysammaguda, Gundlapochampally(V) Medchal(M) in Medchal Town section of Medchal Subdivision in Operation division Medchal in RRN.Circle under Capital Works.

Division : SE/OP/GHYD WEST	Section : AE MEDCHAL TOWN
Project Type : SC-Extension of Supply (HT-11KV)	Cost Center : 107311101
Estimate No. : E-2015-07-03-11-01-088	Estimate Description : HT20011996Estimate for e/s under 11KV H
Network No. : 520000162376	Estimate Created Date : 16.01.2016
Reservation No. :	Plant : 1060
User Status : DE NBGD	System Status : CRTD AVAC
Estimate Approved date :	Estimate Sanctioned By :

Work to be executed by : CONSUMER

CSC Ren no.	Appl. Name	HT/ LT	Cat. 1	Sub. Cat.1	C.L1	Cat. 2	Sub. cat.2	C.L2	Bi- Mon.	Doc. Rec.	Ser. Con.	Exst. Load
HT20011996	M/S. C.M.R EDUCATIONAL SOCIETY	HT	02	011	100.00	00	00	0.00		X		70.00

		Estimate Cost (Gross) :	0.80
		Less Credits :	0.00
		Estimate Cost (Net) :	0.80
		10% Incidental Charges to be collected :	0.07
SL.No.	-Proposals involves	Total in Rs.	
1	10 - MATERIAL DATA	0.8015	

Superintending Engineer  
Operation Circle, Ranga Reddy (North)  
T.S.P.D.C.L., Gunrock, Secunderabad-15.

**PRINCIPAL**  
**Nalla Reddy Engineering College**  
**(Autonomous)**  
**Maisammaguda, Dhulapally,**  
**(Post Via Kompally), Sec'bad-500 100**

**SOUTHERN POWER DISTRIBUTION COMPANY OF TELANAGANA. LIMITED**

**REPORT TO ACCOMPANY THE ESTIMATE**

- 1 **General :** The proposal is for Extension of HT Supply at 11 KV under Cat-II for an addl CMD of 30 KVA without change in CL over and above the existing CMD 70 KVA with a CL of 100 KW making a total CMD of 100 KVA with a CL of 100 KW to M/s. C.M.R Educational Society., (RRN-2001), at Sy.Nos. 592 & 593, Maisammaguda (V), Medchal (M) in Medchal Town Section of Medchal Sub-Division in Medchal Division in Ranga Reddy Circle (North)
- 2 **Main Features :** The Proposal envisages the following.
  - a The existing 11 KV HT Metering arrangement is quite adequate to cater the existing as well as proposed loads now.
  - b Effecting of 1 No. HT Service for an addl CMD of 30 KVA without change in CL over and above the existing CMD 70 KVA with a CL of 100 KW making a total CMD of 100 KVA with a CL of 100 KW.
- 3 **33/11 KV Substation and Feeder :** The proposed loads are on 11 KV Malla Reddy whose load is 30Amps emanating from 33/11 KV G.P.Pally SS with existing Power Transformer Capacity 2 x 8 MVA is quite adequate to cater the proposed loads, already proposed loads and existing loads.
- 4 **Capital Cost of the Estimate :-** The total cost of the estimate is Rs. Nil/- and it is self remunerative.
- 5 **H.T. Regulation :-** The H.T. Regulation of the feeder calculated and found within permissible limits.

*Ure*  
*AEIT*  
*AEIT*  
*DETO*  
Superintending Engineer  
Operation Ranga Reddy Circle (North)

*APK*  
**PRINCIPAL**  
**Malla Reddy Engineering College**  
**(Autonomous)**  
**Maisammaguda, Dhulapally,**  
**(Post Via Kompally), Sec'bad-500 100**



# SOUTHERN POWER DISTRIBUTION COMPANY OF TELANGANA LIMITED

Office of  
Superintending Engineer  
Operation Ranga Reddy Circle (North),  
Gunrock, Secunderabad.

HT Addl. II

WBS No.E-2015-07-03-11-01-088

Sanction Memo No. SE/O/RRCN/Tech./DR. No.298/15.D. No.1540/15-16, dt. 01-02-16.

Sub :- Electricity, Operation, Ranga Reddy Circle (North) – Extension of HT Supply at 11 KV under Cat-II for an addl CMD of 30 KVA without change in CL over and above the existing CMD 70 KVA with a CL of 100 KW making a total CMD of 100 KVA with a CL of 100 KW to M/s. C.M.R Educational Society., (RRN-2001). – Estimate sanctioned.

Ref :- Lr. No. DEE / OP /MDECL/Comml./F.Capital./D.No. 2977/15, Dt: 28-01-2016:

\*\*\*\*\*

The Superintending Engineer, Operation, Ranga Reddy Circle North administratively approves the proposal for Extension of HT Supply at 11 KV under Cat-II for an addl CMD of 30 KVA without change in CL over and above the existing CMD 70 KVA with a CL of 100 KW making a total CMD of 100 KVA with a CL of 100 KW to M/s. C.M.R Educational Society., (RRN-2001), at Sy.Nos. 592 & 593, Maisammaguda (V), Medchal (M) in Medchal Town Section of Medchal Sub-Division in Medchal Division in Ranga Reddy Circle (North) and accords sanction for

Rs. 0

Nil

towards expenditure as per the detailed estimate enclosed.

The estimate is technically sanctioned and registered as D.R. No. 298/ 2015-16

a.

## CHARGEABLE TO CAPITAL :

	Rs.	Rs.
A. T.S.S.P.D.C.L.'s Side	Rs.	0
B. Consumer's Side	Rs.	0
C. TOTAL	Rs.	0

The classification of expenditure is given below :

T.S.S.P.D.C.L. – Capital out lay on electricity scheme – E. Arrears (B) Expenditure (3) Distribution System (Excluding S.S.) F. Distribution Plant (High Voltage) D. Distribution Plant (Medium and Low voltage).

T.S.S.P.D.C.L. – Capital out lay on Electricity Scheme – E.H. Arrears B-12 suspense stock.

The sanction accorded is subject to the following conditions.

- 1 Supply is liable to be suitable staggering, restricted, reduced out of altogether, if so arranged by Power fuel or water position or any other emergency.
- 2 Supply is liable to be disconnected, if used without permission of T.S.S.P.D.C.L. for purpose other than those for which it specifically sanction.
- 3 Supply is liable to be disconnected, if any of the above conditions are violated.

**PRINCIPAL**  
**Malla Reddy Engineering College**  
**(Autonomous)**  
**Maisammaguda, Dhulapally,**  
**(Post Via Kompally), Sec'bad-500 100**

- 4 The proposed power to the premises should not have second service no arrears pending and no court cases.  
5 There should not be any 11 KV/LT lines passing through from other source of supply in the proposed premises.

- a) Rs. - Nil - (Rupees - Nil - only) towards non-refundable service line charges.  
b) 36000 Rupees Thirty Six Thousand Only  
towards non-refundable load development charges.  
c) 30000 Rupees Thirty Thousand Only  
towards Security Deposit.

The work order approval is accorded in para (1) above shall be sanctioned by Divisional Engineers, Concerned subject to budget provision & in accordance with the policy laid down by the T.S.S.P.D.C.L., from time to time.

Work order should be issued only on receipt of a certificate along with W.O. application from the concerned Asst. Divisional Engineer to the effect that necessary agreement has been collected.

Against the lump-sum provisions made in the estimate, detailed working estimate should be got approved by the competent authority.

The prospective consumer should give an under taking along with HT Power requisition that in the event of connecting up additional connected load in the premises, in excess of the contracted load requisition he shall be liable to pay the charges for violation.

Encl. : Estimate in the full shape.

*Sd/-*  
Superintending Engineer  
Operation Ranga Reddy Circle (North)

To  
The Divisional Engineer/Operation/Medchal  
Copy to : The Senior Accounts Officer/Expenditure/RR (North) Circle.  
Copy to : The Asst. Divisional Engineer/Operation/Medchal  
Copy to : The Asst. Engineer/Operation/Medchal Town  
Copy Submitted to the Chief General Manager/Comm./TSSPDCL.  
Copy Submitted to the Chief General Manager/Operation/Ranga Reddy Zone.

FORWARDED BY ORDER

*Sd/-*  
Asst. Divisional Engineer/Comm.  
Gunrock, Secunderabad - 15.

*AP/*  
**PRINCIPAL**  
**Malla Reddy Engineering College**  
**(Autonomous)**  
**Maisammaguda, Dhulapally,**  
**(Post Via Kompally), Sec'bad-500 100**

**SOUTHERN POWER DISTRIBUTION COMPANY OF T.G. LIMITED**

Extension of HT Supply at 11 KV under Cat-II for an addl CMD of 30 KVA without change in CL over and above the existing CMD 70 KVA with a CL of 100 KW making a total CMD of 100 KVA with a CL of 100 KW to M/s.-C.M.R Educational Society., (RRN-2001), at Sy.Nos. 592 & 593, Maisammaguda (V), Medchal (M) in Medchal Town Section of Medchal Sub-Division in Medchal Division in Ranga Reddy Circle (North).

### Development Charges

Additional CMD = 30 KVA.

Development Charges @ Rs. 1200/- per KVA  
= 30 KVA x 1200

Rs. 36000

### Additional Security Deposit

30 KVA

Security Deposit @ Rs. 1000/- per KVA

$$30 \text{ KVA} \times 1000$$

= Rs. 30000/-

Superintending Engineer  
Operation Ranga Reddy Circle (North)

**PRINCIPAL**  
**Maila Reddy Engineering College**  
**(Autonomous)**  
**Maisammaguda, Dhulapally,**  
**(Post Via Kompally), Sec'bad-500 100**





# SOUTHERN POWER DISTRIBUTION COMPANY OF TS LIMITED

Activity No : 10

Activity Description : MATERIAL DATA

S.No	Services Code	Services Text	Item Catagory	Quantity	Unit	Rate in Rs.	Amount in Rs.
1	SWR21634	M.S Nuts&Bolts, Washers & Spring Washers	-	0.010	KG	70.00	0.70
Service Cost							0.70
14.5% Service Tax on Labour & Transport :							0.10
3 % S & H Charges :							0.00
3 % Contingencies on materials:							0.00
10 % Estt. & General Charges :							0.00
Total :							0.80

Handwritten signatures and initials: "Vare", "AET", "DEL", "DE/T", "AD/EL", "AB", "S".

Superintending Engineer  
Operation Circle, Ranga Reddy (North)  
T.S.P.D.C.L., Gunrock, Secunderabad-15.

PRINCIPAL  
Malla Reddy Engineering College  
(Autonomous)  
Maisammaguda, Dhulapally,  
(Post Via Kompally), Sec'bad-500 100

**SOUTHERN POWER DISTRIBUTION COMPANY OF TELANGANA. LIMITED**

From  
Superintending Engineer  
Operation Ranga Reddy Circle (North),  
Gunrock, Secunderabad.

To  
M/s. C.M.R Educational Society., (RRN-2001),  
Sy.Nos.592 & 593, Maisammaguda (V), Medchal (M)  
Medchal (M), R.R.Dist.

WBS No.E-2015-07-03-11-01-088

Lr. No. SE/O/RRCN/Techl./DR. No.298/15, D. No. 1541/15-16, dt: 01-02-16.

Sir,

Sub :- Electricity, Operation in Ranga Reddy Circle (North) - Extension of HT Supply at 11 KV under Cat-II for an addl CMD of 30 KVA without change in CL over and above the existing CMD 70 KVA with a CL of 100 KW making a total CMD of 100 KVA with a CL of 100 KW to M/s. C.M.R Educational Society., (RRN-2001), at Sy.Nos. 592 & 593, Maisammaguda (V), Medchal (M) in Medchal Town Section of Medchal Sub-Division in Medchal Division Estimate sanctioned - Intimation of Payments to be made - Regarding.

Ref :- 1.Sanction Memo No.SE/O/RRCN/Techl./DR.No.298/15,D.No.1540/15-16, Dt: 01-02-16.

2.Memo.No. CGM(Comm)/SE(C)/DE(C)/ADE-I/D.No.1722/13.Dt.17-08-13

\*\*\*\*\*

Extension of HT Supply at 11 KV under Cat-II for an addl CMD of 30 KVA without change in CL over and above the existing CMD 70 KVA with a CL of 100 KW making a total CMD of 100 KVA with a CL of 100 KW to M/s. C.M.R Educational Society., (RRN-2001), at Sy.Nos. 592 & 593, Maisammaguda (V), Medchal (M) in Medchal Town Section of Medchal Sub-Division in Medchal Division in Ranga Reddy Circle (North) is approved vide reference cited. you are requested to comply with the following.

To pay an amount of Rs. 66000 Rupees Sixty Six Thousand Only


towards Development charges & towards Security Deposit by DD drawn in favour of TSSPDCL, and hand over to CSC/Medchal

Enter into HT agreement on a non-judicial stamp paper of Rs. 100/- in the prescribed proforma in Superintending Engineer Operation / Ranga Reddy Circle (North) for a CMD of 100 KVA.

Furnish approval of CEIG of A.P. for your electrical installation.

Furnish approval of Pollution Control Board.

Yours faithfully,

  
Superintending Engineer  
Operation Ranga Reddy Circle (North)

Copy to SAO/RR Circle (North)/Gunrock.

Copy to the Divisional Engineer/Operation/Medchal

Copy to the Asst. Divisional Engineer/Operation/Medchal.

Copy Submitted to the Chief General Manager/Comm./TSSPDCL

Copy Submitted to the Chief General Manager/Operation/Ranga Reddy Zone.

**PRINCIPAL**  
**Malla Reddy Engineering College**  
**(Autonomous)**  
**Maisammaguda, Dhulapally,**  
**(Post Via Kompally), Sec'bad-500 100**





**SOUTHERN POWER DISTRIBUTION COMPANY OF T.S. LIMITED**  
**MEDCHAL CSC**

**PAYMENT ACKNOWLEDGEMENT**

Received the Payment With Thanks From Smt/Sri M/S. C.M.R EDUCATIONAL SOCIETY against the Estimation Charges for a Additional Load of HT service connection.

**HT Reference No : HT20011996**

**Date of Registration : 04-JAN-2016**

Service Number	RRN2001
FIRM Name	M/S. C.M.R EDUCATIONAL SOCIETY
Address	SY.NO.592 & 593,MAISAMMAGUDA(V ,GUNDLA POCHAMPALLY,,II,R.R.DIST
Category	HT-II
Contracted MAX Demand Req.	100 KVA
Registered Purpose	Additional Load

**Payment Details:**

PRNO	Cheque_DD_Number	Cheque_DD_Date	Amount	Bank_Name
10502018750	664073	06/02/2016	66000	UNION BANK OF INDIA

**Other Details:**

Security Deposit	Development Charges	SLC	SC	Others
30000.0	30000.0	0.0	0.0	0.0



Print

**PRINCIPAL**  
**Malla Raddy Engineering College**  
**(Autonomous)**  
**Malsammaguda, Dhulapally,**  
**(Post Via Kompally), Sec'bad-500 100**